

THIS SECTION IS BASED ON ROCKFON'S "INFINITY™" D DRYWALL METAL PERIMETER TRIM.

Rockfon Infinity™ D Drywall Metal Perimeter Trim is meant for interior applications, Specifications as shown here pertain to interior applications only.

Contact Rockfon for guidelines specifically applicable to exterior use of Rockfon Infinity™ D Drywall Metal Perimeter Trim products.

GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes: Provide suspended ceiling acoustical ceiling panels including but not limited to:
 - 1. Metal Perimeter Trim.
- B. Related Sections:
 - 1. Section 09 21 16, Gypsum Board Ceilings.
 - 2. Section 09 52 23, Metal Acoustical Ceiling Suspension Assemblies.
 - 3. Section 09 54 00, Specialty Ceilings.
 - 4. Section 09 58 00, Integrated Ceiling Assemblies.
 - 5. Section 01 81 13, Sustainable Design Requirements
 - 6. Section 01 81 19, Indoor Air Quality Requirements
 - 7. Section 13 48 00, Sound, Vibration, and Seismic Control.
 - 8. Section 23 50 00, Central Heating Equipment.
 - 9. Section 26 50 00, Lighting.

1.3 REFERENCES

- A. Abbreviations and Acronyms:
 - 1. ASTM: American Society for Testing and Materials
 - 2. Cisca: Ceilings & Interior Systems Construction Association; www.cisca.org.
 - 3. IBC: International Building Code
 - 4. ASCE 7 American Society of Civil Engineers, Minimum Design Loads for Buildings and Other Structures
 - 5. ICCES: International Code Council-Evaluation Services - AC 156 Acceptance Criteria for Seismic Qualification Testing of Non-structural Components
 - 6. ICCES: International Code Council-Evaluation Services Report - ESR 2631 Rockfon Chicago Metallic Corporation Suspended Ceiling Framing Systems and Suspension Ceiling Systems
 - 7. California Department of Public Health CDPH/EHLB Emission Standard Method Version 1.1 2010

8. LEED - Leadership in Energy and Environmental Design is a set of rating systems for the design, construction, operation, and maintenance of green buildings
9. International Well Building Standard
10. Mindful Materials
11. Living Building Challenge

B. Reference Standards:

1. ASTM A1008 Standard Specification for Steel, Sheet, Cold Rolled, Carbon, Structural, High-Strength Low-Alloy and High-Strength Low-Alloy with Improved Formability
2. ASTM A641 Standard Specification for Zinc-Coated (Galvanized) Carbon Steel Wire
3. ASTM A653 Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) by the Hot-Dip Process
4. ASTM B221-20 Standard Specification for Aluminum and Aluminum Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes
5. ASTM C635/C635M Standard Specification for Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings
6. ASTM C636/C636M Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels
7. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials
8. ASTM E580 Standard Specification for Installation of Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels in Areas Subject to Earthquake Ground Motions

C. Alternates

1. Prior Approval: Unless otherwise provided for in the Contract documents, proposed product substitutions may be submitted no later than TEN (10) working days prior to the date established for receipt of bids. Acceptability of a proposed substitution is contingent upon the Architect's review of the proposal for acceptability and approved products will be set forth by the Addenda. If included in a Bid are substitute products that have not been approved by Addenda, the specified products shall be provided without additional compensation.
2. Submittals that do not provide adequate data for the product evaluation will not be considered. The proposed substitution must meet all requirements of this section, including but not necessarily limited to, the following: Single source materials suppliers (if specified in Section 1.5); Underwriters' Laboratories Classified Acoustical performance; Panel design, size, composition, color, and finish; Suspension system component profiles and sizes; Compliance with the referenced standards.

1.4 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Meetings: Conduct meeting at Project site. Agenda includes Project conditions, coordination with work of other trades and layout of items which penetrate ceilings.

1.5 SUBMITTALS

- A. Product Data: Submit manufacturer's Product data, including suspension system and maintenance data.

- B. Samples: Submit samples of specified ceiling perimeter trim.
- C. Show Drawings: Necessary technical drawings and documents that pertain to the layout of the acoustical metal ceiling.
- D. Certifications: Acoustical metal ceiling product's certifications that confirm compliance with applicable tests and standards. Acoustical metal ceiling products must also contain information pertaining to certification for NRC.

1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Supply additional material (full-size ceiling panels) equal to [] of ceiling area. Additional material should match Products installed and have the appropriate labels and identification.
- B. Supply extra materials that match Products installed and are packaged with protective covering for storage and identified with labels describing contents.

1.7 QUALITY ASSURANCE

- A. Single-Source Responsibility: Provide acoustical panel units and grid components by a single manufacturer.
- B. Fire Performance Details: Suspension ceiling components will feature markings of applicable testing and inspecting organization.
- C. Coordination of Work: Coordination between installers and other related professions in reference to acoustical ceiling work can include electrical fixtures and systems, fire safety systems, gypsum and building construction.

1.8 DELIVERY, STORAGE, AND HANDLING

- A. Protect system components from excessive moisture in shipment, storage, and handling. Deliver in unopened bundles and store in a dry place with adequate air circulation.

1.9 WARRANTY

- A. Manufacturer Warranty: Submit a written warranty executed by manufacturer for a period of 1 year from date for metal ceilings, of Substantial Completion, agreeing to repair or replace suspension system components that fail or are compromised within the specified warranty period. Failed or compromised parts can include, but are not limited to:
 - 1. Rusting or defects directly made by the manufacturer.
 - 2. Sagging or warping directly made by the manufacturer.

PART 2 - PRODUCTS

2.01 Manufacturer

- A. Aluminum Perimeter Trim:
 - 1. Rockfon, 4849 South Austin Avenue, Chicago, IL 60638. 1-800-323-7164; www.rockfon.com.
- B. Metal Ceiling Systems:

1. Rockfon, 4849 South Austin Avenue, Chicago, IL 60638. 1-800-323-7164;
www.rockfon.com.

C. Suspension Systems:

1. Rockfon, 4849 South Austin Avenue, Chicago, IL 60638. 1-800-323-7164;
www.rockfon.com.

2.02 MATERIALS

A. Acoustical Metal Trim: Metal Perimeter Trim, "INFINITY™" D DRYWALL METAL PERIMETER TRIM" by Rockfon with following characteristics:

1. Surface: Smooth
2. Composition: Metal
3. Material: 6063-T5 aluminum
4. Edges: [SQ]
5. Height [4"] [6"]
6. Fire Class: Class A.:
7. Recycled Content: 85%

B. Panels and Accessories:

1. Perimeter Trim:
 - a. Manufactured from extruded 6063-T5 aluminum complete with continuous integral slots for attachment of splice plates and grid clips.
2. Profile:
 - a. Rockfon Infinity D profile for 5/8" drywall ceilings, (4)(6) inch high with 1 inch horizontal face taping flange grooved to accept joint compound. Panels to be (straight)(curved) as indicated on approved drawings. Outer surface to be primed for adhesion of joint compound and field applied paint finish. Field applied paint color to be (_____).
3. Splice Plate:
 - a. Manufactured from galvanized steel with set screw for splicing sections of perimeter trim.
4. Grid Clips:
 - a. Manufactured from galvanized steel with set screw for attaching perimeter trim to suspension system members.

C. Suspension System:

1. Main Tees:
 - a. Manufactured from cold rolled steel formed to (1-3/8) inch wide face x 1 ½ inch height. Ends of tees to be factory cut to length and notched to provide flush fit to perimeter trim.
2. Cross Tees:
 - a. Manufactured from cold rolled steel formed to (1-3/8) inch wide face x 1 ½ inch height. Ends of tees to be factory cut to length and notched to provide flush fit of perimeter trim.

EXECUTION**1.10 EXAMINATION**

- A. Examine suspension assemblies, with installer present, for compliance with requirements specified in this and other Sections affecting ceiling panel installation and with requirements for installation tolerances and other conditions affecting performance of acoustic ceiling assemblies.
- B. Verify actual field dimensions prior to installation.
- C. Verify adequate support for Rockfon Infinity Perimeter Trim prior to installation.
- D. Infinity for drywall sections to be cleaned on site prior to field painting.

1.11 INSTALLATION

- A. Install ceiling perimeter trim to comply with ASTM C636/C636M, ASTM E580, and seismic design requirements indicated, according to manufacturer's written instructions and CISCA's "Ceiling Systems Handbook".
- B. Infinity Perimeter Trim:
 - 1. Install after completion of above ceiling work.
 - 2. Install ceiling suspension system as specified and in accordance with ASTM C636.
 - 3. Install Infinity perimeter trim in accordance with manufacturers printed instructions and details and approved shop drawings.
 - 4. Infinity perimeter trim to be supported by ceiling grid suspension system.
 - 5. Attach splice plates and tighten set screws to join perimeter trim.
 - 6. Attach trim to main tees and/or cross tees with grid clips. Field measure and cut tees to length. Attach grid clips to perimeter trim by inserting into grooves and firmly tighten set screw. Attach grid clips to main tees and cross tees with sheet metal fasteners (by contractor).
 - 7. Field paint Infinity for drywall sections after drywall, taping, joint compound and sanding is complete.
- C. Field Quality Control
 - 1. Maximum deflection not to exceed 1/360 of the span.
- D. Perimeter Treatment:
 - 1. Perimeter treatment: Install channel on vertical surfaces, intersecting suspension components, by appropriate method in accordance with industry accepted practice.
 - 2. Additional Hanger Wires at locations where imposed loads could cause deflection exceeding 1/360 of the span.

1.12 REPAIR

- A. Remove damaged or compromised components; replace with undamaged components.

1.13 CLEANING

- A. Clean exposed surfaces in accordance with manufacturer's written instructions.

END OF SECTION