

THIS SECTION IS BASED ON ROCKFON'S "SPANAIR™" CLIP-IN METAL CEILING PANELS.

Rockfon SpanAir™ Clip-In Metal Ceiling Panels are meant for interior applications, specifications as shown here pertain to interior applications only.

GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes: Provide suspended ceiling acoustical ceiling panels including but not limited to:
 - 1. Panel Metal Ceiling System.
- B. Related Sections:
 - 1. Section 09 21 16, Gypsum Board Ceilings.
 - 2. Section 09 51 33.13, Acoustical Snap In Metal Pan Ceiling
 - 3. Section 09 52 23, Metal Acoustical Ceiling Suspension Assemblies.
 - 4. Section 09 54 00, Specialty Ceilings.
 - 5. Section 09 58 00, Integrated Ceiling Assemblies.
 - 6. Section 01 81 13, Sustainable Design Requirements
 - 7. Section 01 81 19, Indoor Air Quality Requirements
 - 8. Section 13 48 00, Sound, Vibration, and Seismic Control.
 - 9. Section 23 50 00, Central Heating Equipment.
 - 10. Section 26 50 00, Lighting.

1.3 REFERENCES

- A. Abbreviations and Acronyms:
 - 1. ASTM: American Society for Testing and Materials
 - 2. Cisca: Ceilings & Interior Systems Construction Association; www.cisca.org.
 - 3. IBC: International Building Code
 - 4. ASCE 7 American Society of Civil Engineers, Minimum Design Loads for Buildings and Other Structures
 - 5. ICCES: International Code Council-Evaluation Services - AC 156 Acceptance Criteria for Seismic Qualification Testing of Non-structural Components
 - 6. ICCES: International Code Council-Evaluation Services Report - ESR 2631 Rockfon Chicago Metallic Corporation Suspended Ceiling Framing Systems and Suspension Ceiling Systems
 - 7. California Department of Public Health CDPH/EHLB Emission Standard Method Version 1.1 2010
 - 8. LEED - Leadership in Energy and Environmental Design is a set of rating systems for the design, construction, operation, and maintenance of green buildings
 - 9. International Well Building Standard

10. Mindful Materials
11. Living Building Challenge

B. Reference Standards:

1. ASTM A1008 - Standard Specification for Steel, Sheet, Cold Rolled, Carbon, Structural, High-Strength Low-Alloy and High-Strength Low-Alloy with Improved Formability
2. ASTM A641 - Standard Specification for Zinc-Coated (Galvanized) Carbon Steel Wire
3. ASTM A653 - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) by the Hot-Dip Process
4. ASTM C423 - Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method
5. ASTM C635/C635M - Standard Specification for Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings
6. ASTM C636/C636M - Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels
7. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber
8. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials
9. ASTM E580 - Installation of Metal Suspension Systems in Areas Requiring Moderate Seismic Restraint
10. ASTM E1111/E1111M - Standard Test Method for Measuring the Interzone Attenuation of Open Office Components
11. ASTM E1414/E1414M - Standard Test Method for Airborne Sound Attenuation Between Rooms Sharing a Common Ceiling Plenum
12. ASTM E1264 - Classification for Acoustical Ceiling Products

C. Alternates

1. Prior Approval: Unless otherwise provided for in the Contract documents, proposed product substitutions may be submitted no later than TEN (10) working days prior to the date established for receipt of bids. Acceptability of a proposed substitution is contingent upon the Architect's review of the proposal for acceptability and approved products will be set forth by the Addenda. If included in a Bid are substitute products that have not been approved by Addenda, the specified products shall be provided without additional compensation.
2. Submittals that do not provide adequate data for the product evaluation will not be considered. The proposed substitution must meet all requirements of this section, including but not necessarily limited to, the following: Single source materials suppliers (if specified in Section 1.5); Underwriters' Laboratories Classified Acoustical performance; Panel design, size, composition, color, and finish; Suspension system component profiles and sizes; Compliance with the referenced standards.

1.4 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Installation Meetings: Conduct meeting at Project site. Agenda includes Project conditions, coordination with work of other trades and layout of items which penetrate ceilings.

1.5 SUBMITTALS

- A. Product Data: Submit manufacturer's Product data, including suspension system and maintenance data.

- B. Samples: Submit samples of specified ceiling panels.
- C. Show Drawings: Necessary technical drawings and documents that pertain to the layout of the acoustical metal ceiling.
- D. Certifications: Acoustical metal ceiling product's certifications that confirm compliance with applicable tests and standards. Acoustical metal ceiling products must also contain information pertaining to certification for NRC.

1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Supply additional material (full-size ceiling panels) equal to [] of ceiling area. Additional material should match Products installed and have the appropriate labels and identification.
- B. Supply extra materials that match Products installed and are packaged with protective covering for storage and identified with labels describing contents.

1.7 QUALITY ASSURANCE

- A. Single-Source Responsibility: Provide acoustical panel units and grid components by a single manufacturer.
- B. Coordination of Work: Coordination between installers and other related professions in reference to acoustical ceiling work can include electrical fixtures and systems, fire safety systems, gypsum and building construction.

1.8 DELIVERY, STORAGE, AND HANDLING

- A. Protect system components from excessive moisture in shipment, storage, and handling. Deliver in unopened bundles and store in a dry place with adequate air circulation.

1.9 WARRANTY

- A. Manufacturer Warranty: Submit a written warranty executed by manufacturer for a period of 1 year from date for metal ceilings, of Substantial Completion, agreeing to repair or replace suspension system components that fail or are compromised within the specified warranty period. Failed or compromised parts can include, but are not limited to:
 - 1. Rusting or defects directly made by the manufacturer.
 - 2. Sagging or warping directly made by the manufacturer.

PART 2 - PRODUCTS

2.01 Manufacturer

- A. Metal Ceiling Systems:
 - 1. Rockfon, 4849 South Austin Avenue, Chicago, IL 60638. 1-800-323-7164; www.rockfon.com.
- B. Suspension Systems:
 - 1. Rockfon, 4849 South Austin Avenue, Chicago, IL 60638. 1-800-323-7164; www.rockfon.com.

- C. Aluminum Perimeter Trim:
1. Rockfon, 4849 South Austin Avenue, Chicago, IL 60638. 1-800-323-7164; www.rockfon.com.

2.02 MATERIALS

- A. Acoustical Metal Panels: Panel Metal Ceiling System, "SPANAIR™" CLIP-IN METAL CEILING PANELS" by Rockfon with following characteristics:

1. Surface: Smooth
2. Composition: Metal
3. Material: 0.032" Aluminum
4. Edges: [SQ]
5. Color:
6. Perforation Option:
7. NRC:
8. Fire Class: Class A.
9. Light Reflectance:
10. Recycled Content: up to 85%

- B. Panels and Accessories:

1. ROCKFON SpanAir Clip-in panels:
 - a. Panels shall measure (2 x 2), (2 x 4) or custom size (___x ___) with square edge detail. with 90-degree upturned legs, and formed to allow insertion of leaf springs in horizontal legs with pre-punched holes and clips in pre-punched slots in vertical legs, on opposing sides for securing panels to and concealing suspension grid.
 - b. Panels formed from (.032) aluminum (perforated with ROCKFON pattern []) (Other, premium perforation) to provide a _____% open.)
 - c. Aluminum panels shall be painted with a enamel coat finish or adhesive bonded simulated wood grain laminate (aluminum only)
2. Insulation:
 - a. Poly-encased insulation pads, of (1),(1-1/2) thickness and a density of (1), (1 1/2) pcf.
3. Plank Inlay:
 - a. Type I - Acoutex acoustical non-woven fiber to be inserted in the factory and adhered to the back of the panel for sound absorption capabilities.
4. Wall Channel:
 - a. Formed from 0.024 aluminum and manufactured to a C-shape. Length is 120".
5. Wall Angle:
 - a. Formed from 0.024 (aluminum) (galvanized steel), and manufactured to an L-shape, with a 15/16 inch bottom leg and 2 3/4 O.D. Length is 120"
6. Infinity Perimeter Trim: Made from extruded aluminum ((4), (6), (8), (10), (12)) inches deep. Painted exposed faces or on all sides to match panels.
7. Hold-Down Insert:
 - a. Formed from the same material, with the exception of the finish, as the wall channel and angle
 - b. Manufactured to a C shape, with (3/4) legs, ([11] or [22] inch) length. Finish shall be supplied by manufacturer.

- C. Suspension System

1. Main Carrier:

-
- a. Chicago Metallic Intermediate-duty or Heavy-duty, Non-rated Double Web Suspension (1200 system with 15/16 inch exposed face) as manufactured by ROCKFON.
 - b. The main carrier shall be formed from [0.020] or [0.015] hot dipped galvanized steel and a length of 144 inches.
2. Cross Tee:
- a. Interlocking cross tees (2 inch and 4 inch) with 15/16 inch exposed face, as manufactured by ROCKFON.
 - b. The cross tee shall be formed from 0.015 hot dipped galvanized steel in lengths of 24 or 48 inches.
- D. Acoustical Material
- 1. Acoutex acoustical non-woven fiber factory adhered to back of perforated panels with 0.70 NRC.
 - 2. Blanket type black vinyl faced one side (1)(11/2) inches thick by (1)(11/2) pounds per cubic foot density with [0.80][0.90] NRC

EXECUTION

2.1.1 EXAMINATION

- A. Examine suspension assemblies, with installer present, for compliance with requirements specified in this and other Sections affecting ceiling panel installation and with requirements for installation tolerances and other conditions affecting performance of acoustic ceiling assemblies.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

2.2 INSTALLATION

- A. Install ceiling panels to comply with ASTM C636/C636M, ASTM E580, and seismic design requirements indicated, according to manufacturer's written instructions and CISCA's "Ceiling Systems Handbook."
- B. Metal panels:
 - 1. Clip-in metal panels with factory inserted springs and clips are appropriately installed in a Chicago Metallic (15/16 inch) grid system, concealed.
 - 2. If necessary, insulation pads shall be laid upon the back of the panels.
 - 3. If necessary, utilize ROCKFON hold down clips to keep the insulation pads in place.
- C. Integrated Accessories
 - 1. Insulation trimmed to fit and installed in plenum between carriers.

1.10 REPAIR

- A. Remove damaged or compromised components; replace with undamaged components.

1.11 CLEANING

- A. Clean exposed surfaces in accordance with manufacturer's written instructions.

END OF SECTION